Appendix 1

ISO 16890-1:2016 - Air Filter Test Results

Testing Organization:
RISE Research Institutes of Sweden AB
Brinellgatan 4, 501 15 Borås, Swedan
+460105165000

GENERAL

Report no.: 7P03107A-rev1	Date of tests: 2017-05-16 - 2017-05-23	Date of report: 2017-11-15
Supervisor: CM		Device obtained (when and how obtained):
Test(s) requested by: Scandcenter AB		The device was sent and obtained on 2017-05-11

DEVICE TESTED

Model: 592x592x635 F7/10 T-G Eco		Manufacturer: Scandcenter AB	Construction: Pocket filter, 10 Pockets
Article number: 7106001TGE	Type of medium: Glass	Net effective filtering area: 8.2 m^2	Filter dimensions (width x height x depth) 592x592x635 mm

TEST DATA AND ATTACHED TEST REPORTS

Test air flow rate: 0.944 m^3/s	Test aersole: KCl (1-10 µm) DEHS (0.3-1 µm)	Test report to ISO 16890-2	Report no. 7P03107A-rev1 Appendix 2
		Test report to ISO 16890-3	Report no. 7P03107A-rev1 Appendix 3
		Test report to ISO 16890-4	Report no. 7P03107A-rev1 Appendix 4

RESULTS

Initial pressure differential: 65 Pa	Initial grav. arrestance: 99 %	$ePM_{1, min}$ 56 %	$ePM_{2.5, min}$ 67 %		ISO rating **ISO ePM_1 55 %**
Final test pressure differential: 300 Pa	Test dust capacity: 1640 g	ePM_1 56 %	$ePM_{2.5}$ 67 %	ePM_{10} 89 %	

Remarks:



NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.